

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s)	Tracking No.	Year
EN 60598-2-3:2003/A1:2011	3.6.3	DSH 0935B	2019
Category			
LITE			
Subject	Keywords	Developed by	Approved at
Wind force test	<ul style="list-style-type: none"> - Complete luminaire - Two fixing devices - Risk of falling 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>According the third paragraph of sub clause 3.6.3 parts of the luminaire shall have extra protection against falling, in case a fixing device fails:</p> <p>1) must the complete luminaire or every part (glass, ballast, etc.) be considered?</p> <p>2) For a luminaire with two fixing devices, is it necessary to pass all the tests when one of them fails or should it be enough that the luminaire remains in place and is prevented from falling?</p>			
Decision			
<p>1) The complete luminaire must be considered.</p> <p>2) It is not necessary to perform the test with one of the fixing device broken.</p>			
Explanatory notes			
